1120 Monroe Ave NW Grand Rapids MI 49503 Phone: 616.456.4100

at

The following checklist may be used as a guideline prior to requesting a final building inspection. This checklist is not comprehensive. It is intended to assist in identifying common issues which could result in delay of occupancy, reinspections and additional fees.

□ Mechanical Inspection Approved	□ Doors:
☐ Stair Pressure approved by Mech. Insp.	☐ Door swing
☐ Atrium- Smoke Evacuation approved by Mech. Insp	□ Latch side clearance
☐ Balancing Reports	□ Alarm released doors
☐ Electrical Inspection Approved	☐ Gap between edges of doors and jamb
☐ Generator Test	□ Sill (thresholds required for combustible floors at
☐ E-light (photometrics)	rated doors, NFPA 80 [2001 edition, 1-11.2]
☐ Fire Inspection Approved	□ Closers
☐ Suppression	□ Self-latching
□ Alarms	□ Labels
☐ Fire Extinguishers	☐ Under cut gap
□ Knox Box	□ Rated Walls need to be identified
□ Plumbing Inspection Approved	□ Special Inspection Final Reports: Concrete,
☐ State Fire (life safety approved as required)	masonry, fire proofing, smoke control systems, installation of precast units, and EIFS.
☐ Elevator Approved (State requirements)	□ Addresses on Buildings, and on signs for
☐ E-lighting (point by point, photometrics) including	commercial buildings (min 4" on contrasting
stairs, exterior doors, and landings	background)
☐ Exit Signs (location and illuminated on e-power)	☐ Landscape: Stairs, fences, greenery, grading
Stairs:	☐ Flame spread/smoke development documents
☐ Rise, run, nosing, handrails, guards, gates, and	for wall/floor finishes
stairwell signage (floor levels, etc.)	Class A 0-25/0450 Class B 26-75/0-450
□ Illumination	Class C 76-200/0-450
□ Egress Windows	☐ As Builts
☐ Safety Glazing: at hazardous locations (doors,	
stairs, and skylights)	
□ Accessibility:	
☐ Signs: Bathrooms, parking, elevator, directional	
☐ Parking: Location, slope, signs, # of spaces required	
(per plan)	
☐ Turning space at doors and tight corners	
□ Vertical grab bars, height and of back wall (39"-41")	
length 18" min.	
☐ Sink heights (34" max) and work space	
☐ Graspable faucet handles	
☐ Scald guards on sinks	
☐ Toilet seat height 17"-19"	
☐ Ramps: Slope, handrails, guards, curbs, edge	
protection, landings	