

In order to perform a thorough Electrical Plan review, plans and specifications submitted must include the following:	
	Lighting layout
	Circuiting (power layout)
	Switching
	Conductor and raceway sizes
	Wattage schedule
	Service location and riser diagram
	Load calculations
	A proposed method of construction that is drawn with symbols of a standard form
	All conductors are assumed to be copper unless otherwise stated in the plan
	Signature and seal of the licensed architect or engineer who prepared, or supervised the preparation of, the plans and specifications
69	)A-06 doc (2.15.18 LL) www.grandranidsmi.gov/devcenter